

Result of measurement for the environmental radiation (drinking water)

Drinking Water

22:00 March 20, 2011

Month/Day	No.	Time	Result of measurement		
			iodine-131	cesium-134	cesium-137
			(Bq/kg)	(Bq/kg)	(Bq/kg)
March 16th (Wed)	1st	8:00	177	25	33
	2nd	14:30	ND	ND	ND
	3rd	18:00	8	ND	ND
	4th	20:00	7	ND	ND
	5th	22:00	10	ND	ND
March 17th (Thus)	1st	0:00	11	ND	ND
	2nd	8:15	14	ND	ND
	3rd	11:00	21	ND	ND
	4th	14:00	30	ND	ND
	5th	17:00	46	ND	ND
	6th	20:00	136	ND	ND
	7th	23:00	180	ND	ND
March 18th (Fri)	1th	2:00	170	ND	ND
	2th	5:00	162	ND	ND
	3th	8:00	130	ND	ND
	4th	11:00	101	ND	ND
	5th	14:00	61	ND	ND
	6th	17:00	47	ND	ND
March 19th (Sat)	1st	9:00	17	ND	ND
	2th	14:00	25	ND	ND
	3th	18:00	24	ND	ND
March 20th (Sun)	1st	9:00	17	ND	ND
	2th	14:00	19	ND	ND
	3th	18:00	28	ND	ND

Next measurement took place at 14:00 for extraction of samples. The result will be announced after summarization.

ND : Value below the minimum fixed quantity

■ Reference 1

Index related to consumption limit of drinking water based on the index for the consumption limit of food and drinks of "Disaster Prevention for nuclear facilities (Atomic Energy Commission)"

Iodine-131 : 300Bq/kg or over, Cesium : 200Bq/kg or over

■ Reference 2

① Organization of measurement : Fukushima-ken Environmental Radioactivity Monitoring Center Fukushima Branch Office

② Method of measurement : Based on the manual for the method of measurement of radiation (by Education, Culture, Sports, Science, and Technology Ministry)